

Classification Report

Number	22-004486-PR03 (NW-A01-05-en-01)
Owner	E.u.r.o.Tec GmbH Unter dem Hofe 5 58099 Hagen Germany
Product	Burglar resistant single window fastened with E.u.r.o.Tec GmbH concrete frame screw
Designation	System: AFINO-tec AD, A1 RC3, Fasteners made by E.u.r.o.Tec GmbH Shipping name: Weru AFINO-tec AD
Details	Manufacturer WERU GmbH, - Rudersberg; Material Polyvinylchloride (PVC); Attack side Closing face as per EN 12519; Type of opening Tilt and turn; Installation According to the testing documentation of the attached manufacturer's installation instructions; Overall dimensions (W x H) 965 mm x 1177 mm; Hardware: Manufacturer SIEGENIA-AUBI KG, - Wilnsdorf; System TITAN AF; window handle Lockable handle; Safety locking points 13; Air gap restrictor 2; Anti-lift device 1; LSG: Manufacturer WERU GmbH, Rudersberg; Type extraTherm 1.1 Secur-a P5A (44.6); Class P5A acc. to EN 356
Special features	The wall connection was ensured by a concrete frame screw ch 7,5 x 122 mm by E.u.r.o.Tec .

Result **)

Burglary resistance according to EN 1627:2021-06



Class: RC 3

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

29.11.2023



Simon Stüer
Deputy Head of Testing Department
Security/Safety Testing



Thomas Zimmer, M.Sc.
Operating Testing Officer
Security/Safety Testing

Basis *)

EN 1627:2021-06

*) and corresponding national versions (e.g. DIN EN)

Test report: 22-004486-PR03 PB-A01-05-de-02

Representation



Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 8FF-29811